

### Temperature Logger Test

#### Boca Raton Test Results

		<u>Air Temp</u>			
		<u>Average</u>	<u>High</u>	<u>Low</u>	
Test #1	Logger #1	41.5	59.0	28.6	February 15, 2008 to February 19, 2008 Before RDFRESH installation
	Logger #2	37.8	55.2	25.0	
Test #2	Logger #1	36.9	51.4	28.6	February 29, 2008 to March 4, 2008
	Logger #2	34.4	51.8	25.0	
Test #3	Logger #1	36.7	50.4	29.7	March 7, 2008 to March 11, 2008
	Logger #2	35.5	48.0	28.6	
Test #4	Logger #1	35.2	48.9	28.0	March 14, 2008 to March 18, 2008
	Logger #2	33.4	49.5	26.2	

Logger #1 was placed by the front door and Logger #2 was placed in the back of the walk-in. Temperatures were logged by computer once per minute for the entire five day run.

While the average temperature drop was 6.3 degrees at the front door and 4.4 degrees at the back, even more impressive is the 10.1 degree drop in the high temperature which obviously relates to periods of high use and goes a long way in keeping food fresher, longer, as well as lowering the number of compressor runs, thereby saving electric and maintenance costs.